CLOW

Clow Valve Co.

902 South 2nd Street
Oskaloosa, IA 52577

Telephone: 641 673-8611
Fax: 641 673-8269

Effective 2026 (January)

Subject: **Certificate of Compliance – Double Disc Gate Valve**

Clow Valve Company manufactures the C500 Double Disc Gate Valve in the United States of America with compliance to the following criteria.

Product

- AWWA C500, Metal-Seated Gate Valves for Water Supply Service (14" – 48" with 250psi rating)
- AWWA C550, Protective Interior Coatings for Valves and Hydrants
- NFS/ANSI 61, Drinking Water System Components – Health Effects

Materials (where applicable)

- Ductile Iron: ASTM A536 (Grade 65-45-12 minimum strength)
- Gray Iron: ASTM A126 (Class B)
- Copper Alloy:
  - ASTM B16 (C36000)
  - ASTM B98 (C65500)
  - ASTM B584 (C83600, C86700, C87610, C87850, C89833)
  - ASTM B763 (C86700, C87610, C99500)

Compliance with other standards, such as those related to end joint connections, is dictated by compliance with standards listed above. If you have any questions, please call (800) 829-2569 for assistance.

Sincerely,

Matthew Dykema

Matthew Dykema
Engineering & Quality Manager